

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

Skill Sheet No.	FF-I- 708	01-01-05	Candidate Number	
Skill Title: SHUTTING OFF NATURAL GAS SERVICE				
NFPA Objective:	5.3.18	Minimum to pass	4	
PERFORMANCE:				P F

	1.	All Personal Protective Equipment (PPE) is properly worn.				
	2.	Searches area/building for natural gas meter.				
	3.	Using a proper wrench, turns petcock to the “CLOSED” position.				
	4.	Turns any remaining visible valves to the “CLOSED” position.				
	5.	Confirms to examiner that natural gas has been shut off.				